



ADDENDUM #2

RFP 26-006

RIDLING FIELD RENOVATION PHASE 1

This addendum is being issued in response to a question resulting from the mandatory pre-bid meeting on RFP 26-006:

1. For the asphalt demo are we to remove the subbase?

Yes. If a subbase exists the Contractor should remove it during the demolition process.

This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Debby Peete
Finance Specialist
City of Commerce

Company Name _____

Authorized Representative _____