



ADDENDUM #3

RFP 26-011

FY26 LMIG

This addendum is being issued to address a follow-up question submitted regarding RFP 26-011:

- Shankle Heights and North Bowden call for milling, will they be getting full milling? If so, will the full milling go to the dirt or to a depth of 1.5"? **Yes, it will be fully milled to a depth of 1.5 inch**
- What is the right-of-way measurement for Belmont St and Shankle Heights Rd? **50 ft**
- The widening on Belmont St/ Shankle Heights calls for 10 feet widening. Is there a preferred side to widen? Can the widening be split 5 feet on each side? **Yes, the widening will all be on the 495 Shankle heights sides**
- On Belmont St/ Shankle Heights widening, is the City going to remove the stumps and relocate utilities or be responsible for the utilities? **The hydrants will be relocated but the contractor is responsible for removing the stumps**
- On Wood St, will the City be responsible for relocating the utilities(including guy wires for overhead lines) for the widening? **If the guide wires need to be relocated, then the city will take care of that issue**
- Does the City want the loop on Wood Street to be paved over the existing gravel layout? Or will the inner portion of the loop be paved also? **Yes, the loop needs to be fully paved**
- What is the right-of-way measurement for Wood Street? **30 ft**
- Wood St receives 25MM asphalt at a minimum of 4". Will Wood St also receive 1.5" of 9.5MM overlay? **Yes, it will need to be topped by 1.5 inch of 9.5mm**

This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Christy Case
Finance Director
City of Commerce

Company Name _____
Authorized Representative _____